



## FIRE PREVENTION WING - FIRE NO OBJECTION CERTIFICATE

File No: 4730303901

Name and Address of the Premises:	Don Bosco School, D.No.44-13/1-1/1, Carmel Nagar, Gunadala, Vijayawada.
Name of the Owner / Occupier:	Secretary & Correspondent

## Details of Building:

Plot Area (in Sq. Meters)	18666 Sq.Meters
No. of Blocks	ONE
Height of the Building from abutting road level to terrace (in meters)	10.00 Meters

## Floor Wise Occupancy details

S.No.	Floor	Built up area (in Sq. Meters)	Type of Occupancy
1.	Ground Floor	1425.55	Educational
2.	First Floor	1384.48	Educational
3.	Second Floor	1037.14	Educational

## Open spaces in Meters

Front	86.40	Back	15.84	Side - 1	70.40	Side - 2	27.07
-------	-------	------	-------	----------	-------	----------	-------

## Means of Escape (Staircase)

S No.	Details of Staircases	Provided	
		Number	Width in meters
1.	No of Staircases	03	03.80

## Fire Fighting Equipment as show in the Annexure

Renewal of No Objection Certificate is hereby Issued along with Annexure Under Section 13/15 of Andhra Pradesh Fire Service Act, 1999 and under Rule 15 of Andhra Pradesh Fire and Emergency Operations and Levy of Fee Rules 2006 to the above Premises within the Jurisdictions of Vijayawada Municipal Corporation subject to the Maintenance of Fire Fighting Equipment in Good Working and other conditions and details Mentioned in the Annexure.

No Objection Certificate is valid up to 12/08/2021 or till it has been duly cancelled (Whichever is earlier)

Commissioner,  
Vijayawada Municipal Corporation.

Signed by V Prasanna  
Verkatesh I A S  
Date: 02-10-2020 20:53:33  
Reason: Approved

**VIJAYAWADA MUNICIPAL CORPORATION**  
**FIRE PREVENTION WING**  
**ANNEXURE TO FIRE NO OBJECTION CERTIFICATE**  
**Rc.No.4730303901 Dated:18-09-2020**

**Sub:** Vijayawada Municipal Corporation – Fire Prevention Wing - Issuance of Annexure to Renewal of No Objection Certificate for Occupancy to the Existing Education Building of Don Bosco School, D.No.44-13/1-1/1, Carmel Nagar, Gunadala, Vijayawada, Krishna District - Regarding.

- Ref:** 1. N.O.C for Occupancy Rc.No.4730303901 Dt: 13-08-2019 of the Commissioner, Vijayawada Municipal Corporation.  
2. Request letter of the Don Bosco School, D.No.44-13/1-1/1, Carmel Nagar, Gunadala, Vijayawada, Krishna District.  
3. Inspection Report Rc No. 4730303901, Dt: 16-09-2020 of the Officials of Fire Prevention Wing, Vijayawada Municipal Corporation.  
4. G.O.Ms.No.154,M.A & U.D Dept. Dt.13-03-2007.  
5. G.O.Ms.No.174, M.A & U.D Dept. Dt. 24-02-2009.  
\*\*\*\*\*

Vide reference 1<sup>st</sup> cited, No Objection Certificate for Occupancy was issued to Educational Building Don Bosco School, D.No.44-13/1-1/1, Carmel Nagar, Gunadala, Vijayawada, Krishna District.

Vide reference 2<sup>nd</sup> cited, Secretary & Correspondent of Don Bosco School of Education has requested for issue of Renewal of Fire No Objection Certificate for Occupancy to the Education Building of Don Bosco School, D.No.44-13/1-1/1, Carmel Nagar, Gunadala, Vijayawada, Krishna District.

Vide reference 3<sup>rd</sup> cited the Officials of Fire Prevention Wing have reported that they have inspected the building on 16-09-2020 and recommended for the issuance of Renewal of No Objection Certificate for Occupancy for the above Education Building.

**PART – A: GENERAL INFORMATION**

1	Name and Address of the Building with Land Marks	Don Bosco School, D.No.44-13/1-1/1, Carmel Nagar, Gunadala, Vijayawada, Krishna District.			
2	Name and Address of Builder/ a)Developer/Owner b)Occupier/Tenant and Telephone No.s	Secretary & Correspondent, Don Bosco School, D.No.44-13/1-1/1, Carmel Nagar, Gunadala, Vijayawada, Krishna District.			
3	Details of the Management/ Representative present at the time of Inspection	Sl. No.	Name	Designation/ Working as	Contact No.
		1.	Fr.Kishore raju	Secretary	9440869468
4.	Plot Area(in Sq. Meters)	18666.00Sq.Meters			
5.	No. of Blocks	ONE			
6.	Height of the Building from abutting road level to terrace(in meters)	10.00 Meters			

(Contd..P3)

**PART – B: BUILDING INFORMATION**

## 3. a). Open spaces:

Side	Open Space Required as per G.O.119,M.A & U.D, Dt:28-03-2017	Open space available	Deficit
Front (East)	03.00 Meters	86.40 Meters	NIL
Back	06.00 Meters	15.84 Meters	NIL
North	06.00 Meters	70.40 Meters	NIL
South	06.00 Meters	27.07 Meters	NIL

## 1.b). Floor Wise Occupancy details:

Sl. No.	Floor	Built up area (in Sq.Meters)	Type of Occupancy	Occupant Load
1.	Ground Floor	1425.55	Educational	356
2.	First Floor	1384.48	Educational	346
3.	Second Floor	1037.14	Educational	259

## 2. Means of Escape (Staircase):

Details of MOE	Provided	
	No.s	Width in meters
No. of Staircases	3	03.80

## Details of Fire Precautionary Fees remitted:

Sl.No.	DD. No.	Date	Amount	Place
1.	010713	27-08-2020	20,000	South Indian bank

**PART – C: FIRE PROTECTION AND FIRE PRECAUTIONARY MEASURES:**

Minimum Fire Fighting Installations required as per Table-7, Part-IV of NBC-2016.

	Sl No	Fire Fighting Installations	Required	Provided	Deficit
Part A	i	Fire Extinguishers	38 No.s	38 No.s	NIL
	ii	Hose Reel	08 No.s	08 No.s	NIL
	iii	Terrace Tank	10,000 ltrs	10,000 ltrs	NIL
	iv	Fire Pump 450LPM	01 No	01 No	NIL
Part B (Additional Fire Safety)	v	Yard hydrant	02 No.s	02 No.s	NIL
	vi	Manually operated electric Fire Alarm System	02 No.s	02 No.s	NIL
	vii	Two way inlet	01 No	01 No	NIL

(Contd..P3)


The Existing Education Building Don Bosco School, D.No.44-13/1-1/1, Carmel Nagar, Gunadala, Vijayawada, Krishna District is provided with required fire safety measures.

The Fire Safety systems were tested by the committee members during the inspection and Performance found satisfactory. Therefore, this Office has issued Annexure to Renewal of No Objection Certificate for Occupancy to Don Bosco School, D.No.44-13/1-1/1, Carmel Nagar, Gunadala, Vijayawada, Krishna District. Subject to the following conditions.


i	All the Fire protection arrangements shall be maintained in good working condition as seen during inspection.
ii	The escape/ exit routes shall not be kept locked/ blocked or encroached.
iii	All the occupants must know the correct method of operation of the fire fighting system.
iv	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v	All Staff members of the institution shall be trained to operate the fire safety equipments during emergency.
vi	Addition/ alteration if any in the building shall be carried only with the prior permission from this Department.
vii	Mock drills should be conducted for every 3 months.

This Renewal of No Objection Certificate for Occupancy is valid up to 12-08-2021 (For a period of one year only). The Owner / Occupant shall submit application for it renewal duly remitting the prescribed fees, as per G.O.Ms.No. 71, Home (Prisons - A) Dept. Dt. 01-04-2010, two months before the date of renewal.

The Annexure to Renewal of No Objection Certificate for Occupancy is with regard to fire safety only and this is not valid for other claims.

  
Regional Fire Officer,  
Fire Prevention Wing,  
Vijayawada Municipal corporation.

  
18/9/2022  
D.R.

  
18/9/2022